



Results of LArGe cryostat cooling tests

S. Schönert, H. Strecker, G. Zuzel
MPI für Kernphysik, Heidelberg



Outlook



- Design of the LArGe cryostat
- Active cooling concept
- Evaporation/cooling tests
- Summary







Design of the LArGe cryostat


- LArGe to be installed in the GDL
- The cryostat will contain ~1.5 t of LAr
- Tests of Ge detector strings and anticoincidence technique using LAr scintillation
- Active cooling system (LN₂) is foreseen

Design of the LArGe cryostat








LN₂ supply (active cooling)

-  vacuum insulated tubes
-  male connector
-  female connector
-  vacuum insulated valve




LN₂ supply (active cooling)


-  vacuum insulated tubes
-  male connector
-  female connector
-  vacuum insulated valve



LN₂ supply (active cooling)



LN₂ evaporation test




- ❑ Cryostat filled with LN₂, no active cooling, insulation lid (15 cm foamed polystyrene with a super insulation foil) on the top
- ❑ Evaporation rates measured by mass losses (1 kg precision)




LN₂ level meas. precision: ~2 mm
LAr level meas. precision: ~1 mm

(1 cm of LAr = 8.9 kg)

LN₂ evaporation test



LN₂ evaporation test



- Additional insulation: foamed polystyrene and super insulation foil, improved lid




$$R = 1.4 \text{ kg/h}$$



$$L = 77 \text{ W}$$

(design value: 90 W)

LAr evaporation: test with active cooling




LAr evaporation: test with active cooling



LAr evaporation: test with active cooling




LAr mass loss at $F_{LN_2} = 2.0 \text{ kg/h}$ ($1.6 \text{ m}^3/\text{h}$)



LAr evaporation: test with active cooling




T7 (LAr temperature on the surface) as a function of time at nitrogen flow of $F_{LN_2} = 2.0 \text{ kg/h}$ ($1.6 \text{ m}^3/\text{h}$).



LAr evaporation: test with active cooling




Temperature gradient along the neck



LAr evaporation: test with active cooling



LAr losses for different LN₂ flow rates





Summary

- ❑ Additional insulation of the LArGe cryostat is desired: foamed polystyrene under investigation (^{222}Rn emanation, Ge-spectroscopy)
- ❑ Active cooling works as designed, for LN_2 flow rate of 2 kg/h LAr losses are negligible (LN_2 dewar refilling every week)
- ❑ Temperature of LAr/neck wall is a very good indicator of the needed/actual cooling power
- ❑ Vacuum insulated parts are ordered
- ❑ LAr purification/refilling system almost ready
- ❑ Installation at GS early next year (?)