

# GERDA – NIER Risc Analysis

K.T.Knöpfle  
MPI Kernphysik, Heidelberg  
ktno@mpi-hd.mpg.de

GERDA Collaboration Meeting at Ringberg  
12 – 14 February 2007

# New Safety Review (2006)

---

- May 29: A. Scaramelli outlines need for new safety review, new system!  
Proposes **NIER Engineering**, Bologna, which did review for many other LNGS experiments.
- Work on Version 0.2 of Technical Proposal for Safety Review in progress ▶ [www.mpi-hd.mpg/GERDA/TPRO.html](http://www.mpi-hd.mpg/GERDA/TPRO.html)
- Jun 15: Safety meeting at LNGS, with LNGS safety experts, NIER representatives & GERDA representatives ▶ **focus on study of top events.**
- Jul 20 : Meeting with NIER at Bologna; preliminary report:  
▶ **3rd wall helpful but not indispensable!**
- Sep 19: Meeting at CERN, announced as final – but new information  
▶ **evaporation rate must be less than 10000 m<sup>3</sup>/h** (by factor 3 reduced)  
▶ **request to provide more information on time dependence of rate**
- Oct 05: Report on evaporation rate and its reduction to 10000 m<sup>3</sup>/h delivered  
▶ heat transfer for LAr deduced from experiments done at MPI HD
- Nov 16: Meeting at Bologna of Carla and KTK with NIER A; final clarifications
- Dec 06: Draft of final NIER risk analysis delivered : 3 parts,  
see new GERDA safety document page  
▶ [www.mpi-hd.mpg/GERDA/internal/index.html](http://www.mpi-hd.mpg/GERDA/internal/index.html) -> Safety Documentation

# GERDA Safety Documentation Webpage

## Safety Documentation

Implemented by recommendation of GERDA Board.

### General

Technical Proposal, Version 0.2, Draft of 23 June 2006 [pdf](#)

Please provide your safety relevant documents to our GLIMOS, Marco Balata, or to the Technical Coordinator!

### Risc Analyses



[NIBR Preliminary Risc Analysis, Final Versions, December 2006](#)

NIBR: Cryogenic and Water Tank System, Risc Analysis, Technical Analysis - Phase 2, 13 Sep 06, Rev. 1 [pdf](#)

NIBR: Cryogenic and Water Tank System, Risc Analysis, Technical Analysis - Phase 2, 08 Sep 06, Rev. 0 (italian) [pdf](#)

NIBR: Cryogenic and Water Tank System, Preliminary Risc Analysis, Technical Analysis - Phase 1, 08 Sep 06, Rev. 3 [pdf](#)

NIBR: Cryogenic and Water Tank System, Preliminary Risc Analysis, Technical Analysis - Phase 1, 07 Sep 06, Rev. 2 [pdf](#)

NIBR: Annex\_1, References for failure rate data [pdf](#)

TÜV Nord: GERDA cryostat & Basissicherheit, 07 Jul 2005 [pdf](#)

Air Liquide: Safety Relief Devices, Calculation Note [pdf](#)

Air Liquide: FMECA report for Cu cryostat, 01 Jul 2005 [pdf](#)

Air Liquide: HAZOP report for Cu cryostat, 01 Jul 2005 [pdf](#)

Piping and Instrumentation Diagram, 24 Jun 2005 [tif](#)

### Water Tank and Auxiliary Plants

### Cryostat

Details of GERDA cryogenic vessel insulations, Draft of 22 Jan 2007 [pdf](#)

Model Studies of the Gas Exhaust Rate for a Failure Scenario of the GERDA Cryostat, Draft of 05 Oct 2006 [pdf](#)

Technical Specification - Cryogenic Liquid Nitrogen/Argon Vessel, 8 Aug 2006 [pdf](#)

Stainless Steel Cryostat Drawing GC-1001-2006-05 [pdf](#) or [dwg](#)

1.4571 data sheet [pdf](#)

[welding test Antonius Vesselheads](#)

Stainless Steel certificates [pdf](#)

Calculations for cryostat [pdf](#)

### Superstructure

### Safety Documents and Information from LNGS

[Prevention & Protection Service](#) includes Admittance Rules, Safety Guide, LNGS Emergency Plan,

### Operational Procedures Documents



Operational Procedure OPER-GE-001 R.3 [pdf](#)

### Misc

[Stainless Steel Data Sheets, Deutsche Edelstahlwerke](#)

["Applying 'Basissicherheit' to the GERDA cryostat"](#), GERDA safety meeting at LNGS, 5 Jul 2005

RSK-Leitlinien DWR - Rahmenspezifikation Basissicherheit von ... [pdf](#)

Effect of Volumetric Ratio and Injection Pressure on Water-Liquid Nitrogen Interaction [pdf](#)

# New Safety Review (2007)

- Jan 15: Safety meeting at CERN, with LNGS safety experts, NIER representatives & GERDA representatives
  - ▶ final meeting on NIER risc analysis, all participants satisfied  
(summary docu: Details of GERDA cryogenic vessel insulations by KTK)
  - ▶ new 2nd opinion and LNGS concluding document to follow

## NIER Phase 3: Additional Assessment

### Indice

INTRODUCTION.....

A WATER TANK.....

B CRYOSTAT.....

C P.I.D.....

D ACCIDENTAL RELEASE OF ARGON IN HALL A / EMERGENCY.....

E NEW RISK MATRIX ..... 

F CONCLUSIONS AND SUGGESTIONS.....

▶ next page

CONSEQUENCE → FREQUENCY ↓ a) occ/year b) Ev/h	MORTAL OR IRREVERSIBLE	MAJOR	SERIOUS	MINOR	NO RELEVANT EFFECT
<b>Frequent</b> a) > 1 ev/anno b) <1.1*10 <sup>-2</sup> /h					
<b>Probable</b> a) 10 <sup>-1</sup> /anno - 1/anno b) 5.7*10 <sup>-6</sup> /h - 1.1*10 <sup>-4</sup> /h					
<b>Occasional</b> a) 3*10 <sup>-2</sup> /anno - 10 <sup>-1</sup> /anno b) 2.8*10 <sup>-7</sup> /h - 5.7*10 <sup>-6</sup> /h					
<b>Remote</b> a) 3*10 <sup>-3</sup> /anno - 3*10 <sup>-3</sup> /anno b) 2.8*10 <sup>-7</sup> /h - 2.8*10 <sup>-6</sup> /h				Evento N° 1	Evento N° 2
<b>Improbable</b> a) 3*10 <sup>-4</sup> /anno - 3*10 <sup>-3</sup> /anno b) 5.7*10 <sup>-8</sup> /h - 2.8*10 <sup>-7</sup> /h					Evento N° 5 Evento N° 8 Evento N° 9
<b>Not Credible</b> a) < 3*10 <sup>-4</sup> /anno b) < 5.7*10 <sup>-8</sup> /h		Evento N° 6 Evento N° 3	Evento N° 10		

N.B. = Top 1, Events 7 and 11 are not considered in the table because of their occurrence frequencies that are lower than the category "extremely unlikely"

# New Safety Review (2007)

---

## NIER Phase 3: Additional Assessment

### Indice


INTRODUCTION .....	
A WATER TANK.....	
B CRYOSTAT.....	
C P.I.D.....	
D ACCIDENTAL RELEASE OF ARGON IN HALL A / EMERGENCY ..	
E NEW RISK MATRIX .....	
F <u>CONCLUSIONS AND SUGGESTIONS</u> .....	

## F Conclusions and suggestions

- All the accidental conditions analysed and evaluated within a probability range of occurrence with a  $10^{-4} \div 10^{-5}$  ev/year limit, appear to be suitably protected and to have acceptable consequences.
- 1
- Some aspects of the Water Tank – Cryostat system require a final clarification in the right context. This means that it is necessary to specify the final characteristics, the placing and the fixing of the two layers as foreseen. To this purpose we suggest placing the two layers also in the bottom area if possible, as they appear to be useful.
- 2
- Lastly, we suggest once more the differentiation of the staffs in charge of the tests and of the inspections.
- 3

# Cryogenic Vessel Insulations

figure shown / discussed at CERN meeting:





Agreement about implementation of various shields resp. barriers :

- inner vessel - horizontal shell: Makrolon thermal shield, 6mm
- outer vessel - all in contact with water :  
styrofoam, Makrolon 2x 3mm,  
mylar wrap (not finally fixed)

# Layout of the 8 Torlon Support Pads

figure shown / discussed at CERN meeting:



# Conclusions ▶

---

- **New risk analysis by NIER completed.**  
**GERDA safety concept accepted by LNGS.**
  - ▶ cryostat will have internal and external thermal barriers;
  - ▶ waiting for new 2nd opinion and LNGS final safety review document.
- **Webpage for compilation of safety relevant documents initiated.**
  - ▶ Please have a look to be fully informed !
  - ▶ Please submit your relevant documents !